

Build Wholesale Group (Pty) Ltd

ACN : 626 550 043


TEST REPORT

REPORT NUMBER
180702005SHF-BP-1

ISSUE DATE
2018-07-23

PAGES
4

DOCUMENT CONTROL NUMBER
LFT-APAC-SHF-OP-10a
© 2018 INTERTEK



Test Report

Issue Date: 2018-07-23 Intertek Report No. 180702005SHF-BP-1

Applicant: Build Wholesale Group (Pty) Ltd ACN : 626 550 043

Applicant Address:

Attn: Matt

SUBJECT: Performance testing
Poliwood Composite Decking

Dear Sir,

This test report represents the results of our evaluation of the above referenced product(s) to the requirements contained in the following standards:

TEST METHODS AND STANDARDS
Refer to the next following Pages.

SAMPLE ID	MODEL	SPECIFICATION
S180702005SHF.001	/	/

SAMPLE RECEIVED: 2018-06-25
TESTED FROM: 2018-07-02 TO 2018-07-23

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

Test Report

Issue Date: 2018-07-23

Intertek Report No. 180702005SHF-BP-1

Test Items, Method and Results:

Test item	Test Method	Test result
Slip resistance (Oil-wet ramp test)	DIN 51130:2014	Angle: 11.4 ° Rating: R 10

DIN 51130 Classification of Slip resistance (Oil-wet ramp test)

Classification	Angle
R9	6°<X≤10°
R10	10°<X≤19°
R11	19°<X≤27°
R12	27°<X≤35°
R13	>35°

Note:

1. This test was conducted at the external qualified facility, located at Foshan.

Test Report

Issue Date: 2018-07-23

Intertek Report No. 180702005SHF-BP-1

APPENDIX: SAMPLE RECEIVED PHOTO



Fig.1 Front View (Test Face)



Fig.2 Back View

REPORT AUTHORIZED

When signed with physical or electronic signature, the contents of this report have been prepared and approved per Intertek's quality process in accordance with ISO 17025.

Tod Qian



Harris Huang

Name: Tod Qian
Title: Reviewer

Name: Harris Huang
Title: Project Engineer

Revision:

NO.	DATE	CHANGES	AUTHOR	REVIEWER
180702005SHF-BP-1	2018-07-23	First issue	Harris Huang	Tod Qian